MUNICIPAL CORPORATION OF BHILAI

NIT

कार्य का नाम :— पार्षद निधि से वार्ड 10 इस्लाम नगर में असारी बिरयानी के बाजू में बोर खनन कार्य समबर्शिबल पंप सहित कार्य।

(As Per PWD Building SOR 01 01 2015 & Electric SOR 01 06 2020, Non Sor Item)

S.N.	PARTICULERS OF ITEMS	Quantity	UOM
I	Carrying out the resistivity survey by VES method using Schlumberger configuration for locating the proper spot for drilling of tube well within the selected habitation, including photography, interpretation of resistivity data and submission of report in the desired format along with resistivity readings, necessary graph and photographs. (only successful point is payable)	- 1	Point
2	Boring/drilling bore well perfectly vertical for the specified depth suitable to receive required dia for casing/ strainer pipe, by suitable method prescribed in IS: 2800 (part I), including collecting samples from different strata, preparing and submitting strata chart/bore log, including hire & running charges of all equipments, tools, plants & machineries required for the job, all complete as per direction of Engineer–in-charge upto 90 metre depth below ground level.	25.00	METER
	Rocky strata including Boulders.	75.00	METER
3	Boring/drilling bore well perfectly vertical for the specified depth suitable to receive required dia for casing/ strainer pipe, by suitable method prescribed in IS: 2800 (part I), including collecting samples from different strata, preparing and submitting strata chart/bore log, including hire & running charges of all equipments, tools, plants & machineries required for the job, all complete as per direction of Engineer–in-charge upto 90 metre depth below ground level.	40.00	METER
4	Providing and fixing suitable size threaded mild steel cap or spot welded plate to the top of bore well housing/ casing pipe, removable as per requirement, all complete for bore well of:150 mm dia	1.00	Each
5 a h	Supplying, assembling, lowering and fixing in vertical position in bore well, ISI marked G.I. casing pipe (Plain) medium class in 4 to 7 meters length one end fitted with socket as per IS: 239 (Part-1&Part-2) 1992 with 1Vth revision (Up-to-date imendments), of reputed & approved make, including required tire & labour charges, fittings & accessories, all complete, for II depths, as per direction of Engineer- in-charge.	30.00	METER

S.N	. PARTICULERS OF ITEMS		
		Quantity	UOM
6	submersible pump set for water supply system with submersible motor directly coupled to multi-stage submersible pump of specified discharge capacity, head, delivery size in existing bore well including 2 sets of suitable size holding clamps made out of 50 mm X 6 mm MS flat, connection with suitable submersible cable of standard length etc. as per specification and IS: 694 (2010). Note: submersible Cable should be rust proof, safe from oil / Grease and under water Chemical / abrasion Resistant.	1.00	Each
7	Supply, installation, testing and commissioning of 1-3 HP 1 phase submersible motor starter cum control wall/ floor mounted type made out of not less than 1.6 mm thick MS sheet and comprising of following panel mounting switchgears there in including connection inter-connection etc. as per specification. a) Phase indicating lamps with fuses and toggle switches 1 set b) 1/2/3 HP 1 phase DOL starter with over load and no volt relay 1 No c) 25 A "C" curve DPMCB 1 No d) Voltmeter 0-250 V 1 set e) Ammeter 0-10 A 1 set	1.00	Each
8	Supplying and laying following sizes one number FRLS PVC insulated /XLPE, PVC sheathed, steel armoured, aluminium conductor power cable of 1.1 KV grade in existing RCC/HUME/ STONEWARE/ METAL/ HDPE pipe as per specification, IS: 1554 (1988, Part 1) / IS: 7098 (1988, Part 1).	,	METER
ON:	SOR ITEM		
	Providing ISI mark 50 mm dia black H.D.P.E roll pipe with bottom and top socket assembly fiting all complete	100.00	METER
	3 Phase energy meter connection with 4 core 16mm service cable inculding all installation charge	1.00	Nos

Executive Engineer Municipal Corporation Bhilai Asstt.Engineer Municipal Corporation Bhilai

Sub. Eugeneer Municipa Corporation Bhilai