

MUNICIPAL CORPORATION OF BHILAI

NIT


जोन 01 नेहरू नगर अंतर्गत राष्ट्रीय राज्यमार्ग नेहरू नगर चौक से सुपेला चौक तक केबल संधारण कार्य।

As Per Electric SOR 01.01.2015

| S.N. | PARTICULARS OF ITEMS | Quantity | UOM |
|------|--|----------|-------|
| 1 | Supplying and laying following sizes one number FRLS PVC insulated/XLPE, PVC sheathed, steel armoured, aluminium conductor power cable of 1.1 KV grade direct in ground at a depth not less than 40 cm and upto 90 cm including excavation, sand cushioning, protective covering and refilling the trench etc as per specification, IS: 1554 (1988, Part 1) / IS: 7098 (1988, Part 1). 4 x 25 sq. mm. | 2000.00 | Metre |
| 2 | Supplying and fixing PVC water tight terminal box of approved make and brand with detachable gland plate in bottom, hinged front openable cover, rubber gasket, having 1 Nos 4way connector and 1 No SPMCB inside the box for cable connection, fixed to pole with 2 Nos clamp made from 25x3mm GI flat with 2 No GI nuts bolts complete as per specification. 300x200x125 mm for 3 phase | 40.00 | Each |
| 3 | Supplying, fixing and cramping suitable size and all type aluminium ferule/ lugs to following size 1.1 KV grade power cable core / lead, pressed with high pressure cramping tool including connection to switch gear/ MCCB etc as per specification. . 25 sq. mm | 320.00 | Each |
| 4 | Supplying and fixing SP MCB, 240 volts, 'B' curve, suitable for lighting and other loads in the existing MCB DB complete with connections, testing and commissioning etc. as per specification. 6 amps to 32 amps | 100.00 | Each |

Executive Engineer
Municipal Corporation
Bhilai (C.G)

Asstt. Engineer
Municipal Corporation
Bhilai (C.G)


Sub. Engineer
Municipal Corporation
Bhilai (C.G)