

MUNICIPAL CORPORATION OF BHILAI
NIT

(3)

कार्य का नाम :-वार्ड क्रमांक 34 वीर शिवाजी नगर प्रकाश आटा चक्की के पीछे, कुंवर सिंह के घर के पीछे, दुर्गा स्कूल के पास बोर खनन एवं वार्ड के विभिन्न स्थानों में पाईप लाईन विस्तारीकरण कार्य।


AS PER PWD BUILDING S.O.R 01.01.2015 and Electrical SOR 2020, NON SOR

S.N.	P.N.	PARTICULAR	QTY	UNIT
1	21.1.1.3	Boring/drilling bore well perfectly vertical for the specified depth suitable to receive required dia for casing/ strainer pipe, by suitable method prescribed in IS: 2800 (part I), including collecting samples from different strata, preparing and submitting strata chart/bore log, including hire & running charges of all equipments, tools, plants & machineries required for the job, all complete as per direction of Engineer-in-charge upto 90 metre depth below ground level. All types of soil 125 mm dia.	90.00	meter
2	21.1.2.2	Rocky strata including Boulders.125 mm dia.	180.00	meter
3	21.2.2.2	Boring/drilling bore well perfectly vertical for the specified depth suitable to receive required dia for casing/ strainer pipe, by suitable method prescribed in IS: 2800 (part I), including collecting samples from different strata, preparing and submitting strata chart/bore log, including hire & running charges of all equipments, tools, plants & machineries required for the job, all complete as per direction of Engineer-in-charge beyond 90 metre & upto 150 metre depth below ground level. Rocky strata including Boulders. 125 mm dia.	45.00	meter
4	21.5.2	Supplying, assembling, lowering and fixing in vertical position in bore well, ISI marked G.I. casing pipe (Plain) medium class in 4 to 7 meters length one end fitted with socket as per IS: 1239 (Part-1&Part-2) 1992 with IVth revision (Up-to-date amendments), of reputed & approved make, including required hire & labour charges, fittings & accessories, all complete, for all depths, as per direction of Engineer- in-charge. 125 mm dia.	96.00	meter
5	21.1.1.2	Development of tube well in accordance with IS : 2800 (part I) and IS:11189, to establish maximum rate of usable water yield without sandcontent (beyond permissible limit), with required capacity aircompressor, running the compressor for required time till well is fully developed, measuring yield of well by "V" notch method or any other approved method, measuring static level & draw down etc. by step drawdown method, collecting water samples & getting tested in approvedlaboratory, i/c disinfection of tube well, all complete, including hire& labour charges of air compressor, tools & accessories etc., all as per requirement and direction of Engineer-in-charge.	9.00	H
6	21.11.2	Providing and fixing suitable size threaded mild steel cap or spot welded plate to the top of bore well housing/ casing pipe, removable as per requirement, all complete for bore well of: 125 mm dia.	3.00	each

S.N.	P.N.	PARTICULAR	QTY	UNIT
7	19.9.2	Providing and laying in trenches G.I. pipes medium class complete with G.I. fittings including excavation of trenches, refilling the same and testing of joints complete:25 mm dia. nominal bore	156.00	Metre
8	19.9.1	Providing and laying in trenches G.I. pipes medium class complete with G.I. fittings including excavation of trenches, refilling the same and testing of joints complete:15 mm dia. nominal bore	30.00	Metre
9	electric 2020 SOR 23.3.3	Supplying, installation, testing and commissioning of submersible pump set for water supply system with submersible motor directly coupled to multi-stage submersible pump of specified discharge capacity, head, delivery size in existing bore well including 2 sets of suitable size holding clamps made out of 50 mm X 6 mm MS flat, connection with suitable submersible cable of standard length etc. as per specification and IS: 694 (2010). Note: submersible Cable should be rust proof, safe from oil / Grease and under water Chemical / abrasion Resistant. 1.5HP, single phase	3.00	each
10	electric 2020 SOR 23.11	Supply, installation, testing and commissioning of 1-3 HP 1 phase submersible motor starter cum control wall/ floor mounted type made out of not less than 1.6 mm thick MS sheet and comprising of following panel mounting switchgears there in including connection interconnection etc. as required. a) Phase indicating lamps with fuses and toggle switches 1 set b) 1/2/3 HP 1 phase DOL starter with over load and no volt relay 1 No c) 25 A "C" curve DPMCB 1 Nod) Voltmeter 0-250 V 1 set	3.00	Each
11	electric 2020 SOR 23.14. 2	Supplying, laying and fixing following size submersible cable along with GI/PVC/HDFC pipe line or laid in ground etc as per specification and IS: 694 (2010). Note: Cable should be rust proof, safe from oil / Grease and under water Chemical / abrasion Resistant.3x2.5 sqmm	300.00	MT
12	electric 2020 SOR 15.11. 3	Supplying and hanging following sizes one number FRLS PVC insulated /XLPE, PVC sheathed, steel armoured, aluminium conductor power cable of 1.1 KV grade on GI bearer wire (binded at every metre) including cost of bearer wire complete as per specification, IS: 1554 (1988, Part 1) / IS: 7098 (1988, Part 1).2 x 10 sq. mm. on 8 SWG GI bearer wire	90.00	MT
NON SOR RATE				
13	N-s	Providing ISI Mark 32 mm dia Black H.D.P.E Roll Pipe with Bottom and Top Socket Assembly Fiting all Complete	228.00	Metre
14	N-s	02 phase energy meter connection as per CSPDCL Demand Inculding all installation Charge	3	No

कार्यपालन अभियंता
नगर पालिक निगम, भिलाई

सहायक अभियन्ता
नगर पालिक निगम, भिलाई


उप-अभियन्ता
नगर पालिक निगम, भिलाई